

# Kaba Push Button Lock Fire Resistance Performance Statement



On condition that the recommendations given in Assessment Report 176343\* are followed, it can be concluded that the Kaba mechanical and electronic locksets detailed within this report may be fitted to previously tested or assessed (by a NAMAS/UKAS approved laboratory) insulated timber or mineral composite based doorsets to provide 30 minutes or 60 minutes integrity and insulation performance (depending on lockset model and associated intumescent pack), if tested in accordance with BS EN 1634-1:2000.

Push Button Lock Model and Associated Intumescent Pack Summary:

Model	Lock type	Assessed Duration (Mins)	Intumescent Pack Part No.	Description	Door thickness (dependent on FD rating)
7100 series	Tubular Latch/Bolt or Rim lock	30	ITL-KABA-7000-1	Pack 2	44mm
1000 series	Tubular Latch	Up to 60	ITL-KABA-CYLINDER	Pack 1	44 / 60mm
L1000 series	Tubular Latch	Up to 60	ITL-KABA-CYLINDER	Pack 1	44 / 60mm
5000 series	Tubular Latch	Up to 60	ITL-KABA-CYLINDER	Pack 1	44 / 60mm
6200 series	Tubular Latch	Up to 60	ITL-KABA-CYLINDER	Pack 1	44 / 60mm
E-5000 series	Tubular Latch	Up to 60	ITL-KABA-CYLINDER	Pack 1	44 / 60mm
E-5200 series	Tubular Latch	Up to 60	ITL-KABA-CYLINDER	Pack 1	44 / 60mm
E-5700 series	Tubular Latch	Up to 60	ITL-KABA-CYLINDER	Pack 1	44 / 60mm

\* Assessment Report No.176343 by Bodycote Warrington Fire (Now EXOVA Warrington Fire) "The fire resistance performance of timber or mineral composite based insulated doorsets when fitted with Kaba locksets." Plus referenced Test Report No.169456/A "The fire resistance performance of a single-acting, double-leaf timber based doorset and a single-leaf, single-acting timber based doorset incorporating various items of building hardware in accordance with BSEN1634-1: 2000". Are available upon request.

**Disclaimer:** While reasonable efforts were made to ensure the accuracy of this document at the time of printing, Kaba assumes no liability for any errors or omissions. The information is subject to be revised without notice, and changes may be incorporated into future releases. PUB6409LB KLT1209

